

ZB06KAE-PFV

HFC, R-134a, 60 Hz, 1 -Phase, 208/230 V

Medium Temperature



Production Status: Available for sale to all U.S. customers. Please check with your local Emerson Climate Technologies Representative for international availability.

Performance

Evaporator Temp. (°F)	20	45
Condensing Temp. (°F)	120	130
Return Gas Temp. (°F)	65	65
Liquid Temp. (°F)	120	130
Capacity (Btu/hr)	3620	6010
Power (W):	601	690
Current (Amps):	3.35	3.55
EER (Btu/Wh):	6.00	8.70
Mass Flow (lbs/hr):	57	104
<u>Sound Data @ 20 / 120</u>		
Sound Power (dBA):	70 Avg	75 Max
Vibration mils(peak-peak):	2.0 Avg	3.0 Max
Record Date:	2018-01-31	

Electrical

LRA-High*(Amp):	35.7
LRA Low* (Amp):	
LRA-Half Winding (Amp):	
MCC (Amps):	8.4
Max Operating Current(Amp):	5.8
RLA, MCC/1.4;use for contactor selection (Amp):	6.0
RLA, MCC/1.56;use for breaker & wire size selection (Amp):	5.4
RPM:	3500
UL File No:	SA-2337
UL File Date:	2003-12-16
*Low and High refer to the low and high nominal voltage ranges for which the motor is approved.	

Mechanical

Displacment(in^3/Rev):	0.85
Displacment(ft^3/hr):	103.54
Overall Length (in):	9.69
Overall Width (in):	9.69
Overall Height (in):	14.94
Mounting Length (in):	7.50
Mounting Width (in):	7.50
Mounting Height (in):	15.69 *
Suction Size (in),Type:	3/4 Stub
Discharge Size (in),Type:	1/2 Stub
Initial Oil Charge (oz):	25
Oil Recharge (oz):	21
Net Weight (lbs):	46.0
Internal Free Volume (in^3):	139.0
Horse Power:	0.80
*Overall compressor height on Copeland Brand Product's specified mounting grommets.	

Capacitors

Type	Part No	Low MFD	High MFD	Volts	User Description
Start Capacitor	014-0061-27	88.0	106.0	330	OPTIONAL
Run Capacitor	014-0064-07	35.0	0.0	370	

Alternate Applications

Refrigerant	Voltage	Phase	Freq (Hz)	Application
R-404A HFC	208/230	1	60	Medium Temperature
R-507 HFC	208/230	1	60	Medium Temperature
R-407C HFC	208/230	1	60	Medium Temperature
R-407A HFC	208/230	1	60	Medium Temperature
R-407F HFC	208/230	1	60	Medium Temperature
R-448A HFO	208/230	1	60	Medium Temperature
R-449A HFO	208/230	1	60	Medium Temperature